



TEST REPORT

Analysis No. : R24-2233

Received Date: 26/06/24

Customer : Speed Clean Company Limited

Address : 105/10 Moo 9, Tiwanon Road, Pak Kret District, Nonthaburi 11120

Contact : -

Sample Conditions : 2406-WW0654 = clear

Report Date : 05/07/24

Analysis Date : 26/06-01/07/24

Job No. : M/240108

Sampling Date * : 20/06/24

Sampling By * : Customer

Type of Sample : Wastewater

Item	Parameter	Unit	Method	Result	Analysis Date
				2406-WW0654	
				น้ำทิ้งจากการใช้น้ำยาล้างแอร์รถยนต์	
1	pH *	-	Electrometric Method (SM 4500 B)	6.84	26/06/24
2	TSS	mg/L	Dried at 103-105 °C (SM 2540 D)	15.0	27/06/24
3	TDS *	mg/L	Dried at 180 °C (SM 2540 C)	228	01/07/24
4	BOD *	mg/L	5-Days BOD Test, Azide Modification Method (SM 5210 B)	2.0	26/06-01/07/24
5	COD *	mg/L	Closed Reflux Titrimetric Method (SM 5220 C)	26	28/06/24
6	Oil & Grease *	mg/L	Liquid-Liquid, Partition Gravimetric Method (SM 5520 B)	1.2	26/06/24

Remarks * "Test marked "Not TISI Accredited" in this Report are not included in the TISI Accreditation Schedule for our Laboratory"

: BOD มีค่าปริมาณต่ำสุดที่สามารถรายงานเป็นตัวเลขได้ = 2 mg/L

: COD มีค่าปริมาณต่ำสุดที่สามารถรายงานเป็นตัวเลขได้ = 40 mg/L

Method : SM = Standard Method for the Examination of Water and Wastewater, APHA, AWWA, WEF, 24th Edition, 2023

Reviewed by

Ms. Wareerut Prachumdaeng

Chief of Laboratory

05/07/24



Approved by

Mrs. Porntip Pethshee

Laboratory Manager

05/07/24

..... END OF REPORT

- REPORTED RESULTS REFER TO SUBMITTED SAMPLE(S) ONLY
- DO NOT COPY PARTIAL OF THIS ANALYSIS REPORT WITHOUT OFFICIAL APPROVAL